

§ 60.130

10 CFR Ch. I (1–1–05 Edition)

(23) Potential for existing or future perched water bodies that may saturate portions of the underground facility or provide a faster flow path from an underground facility located in the unsaturated zone to the accessible environment.

(24) Potential for the movement of radionuclides in a gaseous state through air-filled pore spaces of an unsaturated geologic medium to the accessible environment.

[48 FR 28222, June 21, 1983, as amended at 50 FR 29647, July 22, 1985; 61 FR 64269, Dec. 4, 1996]

DESIGN CRITERIA FOR THE GEOLOGIC REPOSITORY OPERATIONS AREA

§ 60.130 General considerations.

(a) Pursuant to the provisions of § 60.21(c)(2)(i), an application for construction authorization for a high-level radioactive waste repository at a geologic repository operations area, and an application for a license to receive, possess, store, and dispose of high-level radioactive waste in the geologic repository operations area, must include the principal design criteria for a proposed facility. The principal design criteria establish the necessary design, fabrication, construction, testing, maintenance, and performance requirements for structures, systems, and components important to safety and/or important to waste isolation. Sections 60.131 through 60.134 specify minimum requirements for the principal design criteria for the geologic repository operations area.

(b) These design criteria are not intended to be exhaustive. However, omissions in §§ 60.131 through 60.134 do not relieve DOE from any obligation to provide such features in a specific facility needed to achieve the performance objectives.

[69 FR 2280, Jan. 14, 2004]

§ 60.131 General design criteria for the geologic repository operations area.

(a) *Radiological protection.* The geologic repository operations area shall be designed to maintain radiation doses, levels, and concentrations of radioactive material in air in restricted areas within the limits specified in

part 20 of this chapter. Design shall include:

(1) Means to limit concentrations of radioactive material in air;

(2) Means to limit the time required to perform work in the vicinity of radioactive materials, including, as appropriate, designing equipment for ease of repair and replacement and providing adequate space for ease of operation;

(3) Suitable shielding;

(4) Means to monitor and control the dispersal of radioactive contamination;

(5) Means to control access to high radiation areas or airborne radioactivity areas; and

(6) A radiation alarm system to warn of significant increases in radiation levels, concentrations of radioactive material in air, and of increased radioactivity released in effluents. The alarm system shall be designed with provisions for calibration and for testing its operability.

(b) *Protection against design basis events.* The structures, systems, and components important to safety shall be designed so that they will perform their necessary safety functions, assuming occurrence of design basis events.

(c) *Protection against dynamic effects of equipment failure and similar events.* The structures, systems, and components important to safety shall be designed to withstand dynamic effects such as missile impacts, that could result from equipment failure, and similar events and conditions that could lead to loss of their safety functions.

(d) *Protection against fires and explosions.* (1) The structures, systems, and components important to safety shall be designed to perform their safety functions during and after credible fires or explosions in the geologic repository operations area.

(2) To the extent practicable, the geologic repository operations area shall be designed to incorporate the use of noncombustible and heat resistant materials.

(3) The geologic repository operations area shall be designed to include explosion and fire detection alarm systems and appropriate suppression systems with sufficient capacity and capability to reduce the adverse effects of